

March Production Report

03/07/15 – 04/07/15

GE Jenbacher J-320 Engine

Run Hours:

03/07/15: 16781

04/07/15: 17453

= 672 hours (90% uptime)

Active Energy Counter:

03/07/15: 15147 mw-hr

04/07/15: 15643 mw-hr

= 496 MW HR Produced

GE HRS ORC

Run Hours:

03/07/14: 4432

04/07/15: 4432

= 0 Run Hours (0% Up Time)

Events:

1. ORC still down awaiting Isolation Transformer from IPG and GE. New PE cabinet was installed. GE engineering is scheduling delivery and install.
2. 3/8 Trip
3. 3/14 Utility trip from NIPSCO.
4. 3/19 to 03/20 Down because of well field issues.
5. 3/30 to 3/31 Down because of well field issues.
6. 4/1 Down 2 hours Utility bump from NIPSCO.