

# Energy Systems Group – Munster Landfill | 2015

---

## June Production Report

**06/07/15 – 07/07/15**

### GE Jenbacher J-320 Engine

#### Run Hours:

06/07/15\_ 18727.20

07/07/15\_ 19417.00

= 689.8 hours (95.80 % uptime)

#### Active Energy Counter:

06/07/15\_ 16629.98 MWHR

07/07/15\_17135.14 MWHR

= 505.16 MWHR Produced

### GE HRS ORC

#### Run Hours:

07/07/15: 4432

= 0 Run Hours

### Events:

1. ORC still down. GE was onsite 6/10 and 06/11 for startup. There were additional problems found with the ORC hot water loop. Engine was shut down 06/19 at 0945 to cool ORC Hot Water loop and purge air and refill system. Engine restarted at 06/20 at 1400. IPG was back onsite 07/06 and still could not resolve High Temperature water loop issue. They will be back 07/08 for further testing.