

J & J NEWELL CONCRETE CONTRACTORS, INC.
25350 S STATE STREET
CRETE, ILLINOIS 60417
708-862-1909

February 26, 2024

Town of Munster
Munster Indiana

RE: 2024 Sidewalk Replacement Program:
Addendum 1 Acknowledgement

To Whom it may concern,

We acknowledge we have reviewed Addendum 1 associated with the "2024 Munster Sidewalk Program" and will perform the work as outlined at our original bid price.

Sincerely

A handwritten signature in black ink, appearing to read "Eddie Antonietti", with a stylized flourish at the end.

Eddie Antonietti
Project Manager

DOCUMENT 00 00 11

ADDENDUM NO. 1

February 20, 2024

Town of Munster 2024 Sidewalk Replacement Program

From: Short Elliott Hendrickson Inc.
931 Ridge Road Suite E
Munster, IN 46321

To: Document Holders

DOCUMENT HOLDERS on the above-named project are hereby notified that this document shall be appended to, take precedence over, and become part of the original bidding documents dated January 31, 2024 for this work. Bids submitted for the construction of this work shall conform to this document.

This addendum consists of seven (7) pages.

Changes to Bidding Documents:

1. Revise Section 00 41 00 Bid Form. Original Section to be replace in its entirety.

Revise Article 5 Unit Price Bid Item Description. Remove and replace approximately 1,000 square feet of seven inch (7") thick reinforced portland cement concrete sidewalk compete including concrete removal, earthwood, base material, compaction, and all other work incidental thereto.

General Q&A

1. Are there specifications for watering the seed and straw bedding?
 - a. Watering the seed and straw blanket will be the responsibility of the homeowner. A notice will be provided by the Town of Munster for the residents.
2. Can the contractor stockpile removals such as dirt, tree roots, and other debris at Public Works?
 - a. Yes, the contractor will be allowed to stockpile removals at the Munster Public Works yard.
3. Is there any indication there will be ADA work needed on this project? If so, is there a rough estimate on how much ADA work will be performed?
 - a. Curb ramps aren't anticipated to be included in the project scope.
4. Questions shall be submitted to Kimberly Wenzel, PE at kwenzel@sehinc.com and copy Chris Spolnik at cspolnik@munster.org.

Note: Receipt of this Addendum No. 1, dated February 20, 2024 shall be acknowledged on Page 00 41 00-2 of the submitted Bid Form. Failure to do so may subject Bidder to disqualification.

END OF ADDENDUM


J. Newell - Project Manager
2024 Sidewalk Replacement Program

Addendum No. 1

00 00 11 - 1