

To: President and Members of the Munster Town Council

From: Patricia Abbott
Controller/Interim Town Manager

Date: August 5, 2024

Re: River Bend Pump Station Upgrades and Repairs

The River Bend and Calumet Avenue Pump Stations had new pumps installed in 1994. While proper maintenance has occurred, the time has come to make some repairs and upgrades to include the following.

1. Pump #1 and Pump #3 at River Bend need complete rotating unit replacements. Lead time for the units is six to eight weeks. The cost for this work is \$59,610.00.
2. Pump #3 at Calumet Avenue is currently not working and must be repaired. The total cost for this is \$11,820.00.
3. The existing reservoir fill valve control panel at River Bend is obsolete and needs replacement. This work will include a new SCADA panel, testing, and training. The cost for this work is \$31,872.00.

The total cost for this work is \$103,302.00 and will be paid from the 2024 Water Bond Anticipation Notes.

Recommendation:

By motion and voice vote, approve quotations from Metropolitan Pump Company totaling \$103,302.00 for new rotating unit replacements at Pump #1 and Pump #3 at the River Bend Pump Station, repairs to Pump #3 at the Calumet Avenue Pump Station, and a new reservoir fill valve control panel at the River Bend Pump Station.